PORTABLE APPLIANCE TEST

CERTIFICATE OF COMPLIANCE

Tested by: EKB Contracts

21 James Carter Road
Colchester
Essex CO3 9XA

Property:
SERENDIPITY
54 ELDRED AVENUE
COLCHESTER
ESSEX
CO2 9AR.

Test frequency: Yearly

Test date: 1/9/09.

Appliance Details	Appliance ref:	Class 1 or 2	Inspection of cable	Inspection of plug	Open socket without tool	Cable clamp	Inspection of main switch	Case earth connection	Earth bond (appliance) <0.1/0.25	Earth bond (extension lead) <0.25/0.35	Insulation test >2M/7M	Overall Pass/Fail	Testers initials	Comments
EXTENSION CABLE	001	1	✓	✓	✓	✓	N/A	N/A	N/A	<0·1	>20	PASS	SJA	
EXTENSION CABLE	002	1	✓	✓	✓	✓	N/A	N/A	N/A	<0·1	7	PASS	SJA.	
MARSHALL MG100DFX	003	1	✓	✓	✓	✓	✓	✓	<0·1	N/A	>20	PASS	SJA.	
YAMAHA TYROS 1	004	2	✓	✓	✓	✓	✓	N/A	N/A	N/A	>20	PASS	SJA.	
ALBA CD PLAYER	005	2	✓	✓	✓	✓	✓	N/A	N/A	N/A	>20	PASS	SJA.	
A/TW - R250	006	2	✓	✓	✓	✓	N/A	N/A	N/A	N/A	>20	PASS	SJA.	
SHURE RECEIVER.	007	2	✓	✓	✓	✓	✓	N/A	N/A	N/A	>20	PASS	SJA.	
BOSS ME30 EFFECTS UNIT	008	2	✓	✓	✓	✓	N/A	N/A	N/A	N/A	>20	PASS	SJA.	
EXTENSION CABLE	009	1	✓	✓	✓	✓	N/A	N/A	N/A	<0·1	>20	PASS	SJA.	
BEHRINGER POWERED MIXER	010	1	✓	✓	✓	✓	✓	✓	<0·1	N/A	>20	PASS	SJA.	
EXTENSION CABLE	011	1	X	✓	✓	✓	N/A	N/A	N/A	X	>20	FAIL	SJA	LEAD SCRAPPED.
EXTENSION CABLE BASIX	012	1	✓	✓	✓	✓	N/A	N/A	N/A	<0·1	>20	PASS	SJA.	
SONY MINIDISK PLAYER	013	2	✓	✓	✓	✓	✓	N/A	N/A	N/A	>20	PASS	SJA	